



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728

Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922

North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303

San Diego Service Center: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510

13 February 2020

Volcano CSD

Attn: George Barnes

P O Box 72

Volcano, CA 95689

RE: Source Chemical Monitoring

Work Order: 20A3703

Enclosed are the results of analyses for samples received by the laboratory on 01/30/20 14:05. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Faydra K. Phenix For Karen L. Lantz

Project Manager



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303
San Diego Service Center: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510

Volcano CSD	Project:	Source Chemical Monitoring	
P O Box 72	Project #:	0300016	Reported:
Volcano CA, 95689	Project Mgr:	George Barnes	02/12/20 12:14

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Well 2	20A3703-01	Water	01/30/20 09:00	01/30/20 14:05



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Sample Name: Well 2 Report Date: 02/12/20 12:14
Laboratory ID: 20A3703-01 Laboratory Code: 1610

System Name: VOLCANO COMMUNITY SERVICE DIST Sample Date: 01/30/20 09:00
Source Name: 0300016-002 VOLCANO CSD WELL 02 Sample Received: 01/30/20 14:05
Sampled by: George Barnes User ID: 03C
Employed by: Volcano CSD System Number: 0300016

Data submitted to DDW via EDT

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Nitrate as N	<0.40	10	0.40	mg/L	00618	EPA 300.0	2922

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method	ELAP #
Nitrate + Nitrite as N	<0.40	10	0.40	mg/L	A-029	Calculation	2922
Nitrite as N	<0.40	1	0.40	mg/L	00620	EPA 300.0	2922



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Notes and Definitions

- ND Analyte NOT DETECTED at or above the reporting limit
- * Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 20A3703 Pg _____ of _____

Signature below authorizes work under terms stated on reverse side.

Report to Company: Volcano CSD Attn: Address: PO Box 72, Volcano, CA 95689 Phone/Fax: 209-296-4888 Email Address:		Invoice to (if different) Contact: Email address: Address: Phone/Fax:			Project Information Project ID: SCM N02/N03 (wells 1 & 2) Project No: 0300016 PO Number:					Analysis Request (Signature area)			TAT Standard 10 days Standard 5 days X 48 hours Other: _____ days Lab preapproval required	Temp upon Receipt °C Ukiah temp: Dublin temp: Elk Grove temp: <u>3.6°C</u>																										
Field Sampler - Printed Name & Signature: <u>George Barnes</u>				Container	Preservative		Matrix		Total Number of Containers per Sample ID CV-N02-N DW 300, N03-N DW300 - 250 ml N02+N03-N Calc.	Signature area		Sample Notes or CDPH Source Numbers:																												
Sample Identification Date Time			40ml Vial	Poly	Glass	Sleeve	Other	HCl						HNO3	NaOH	Na2S2O3	NC-16	Water DW	Soil	Other																				
Well 1																																								
Well 2		01-30 09:00																																						
Relinquished by: <u>George Barnes</u>				Received by: <u>[Signature]</u>				Date: <u>1-30-00</u>		Time: <u>1:30</u>		Date: <u>1-30-00</u>		Time: <u>1:45</u>		CDPH Write On EDT Transmission? x Yes No		State System Number: <u>0300016</u>		If "Y" please enter the Source Number(s) in the column above		Mail Hardcopy to DDW - ? Yes No		Hardcopy to DLWW attn:																

FAXED